

Technical Bulletin

Installation: Horizontal flues

SEALING TO THE BUILDING FABRIC

Note: For the purpose of this document, “sealed to” shall mean with a suitable building material or purpose made product. Suitable materials should adhere to the flue and the building fabric and must set firm. Sand & cement is preferred, but expanding foam, silicone sealant and other similar products are suitable.

Non-setting compound is not a suitable material for sealing the annular space.

The requirement for sealing flues to the building fabric where the flue passes through an external wall is for the flue to be sealed to at least one surface of the wall.

Whilst the external rubber wall sealing rings which we provide may well be adequate to prevent rain water or products of combustion from entering the building, they will not secure the final section of flue to the building fabric, which will prevent lateral movement and provide better protection against disconnection of flue sections.

The advice in our manuals is what we consider to be best practice and should be followed.

Our horizontal flue manuals have been updated to contain the following advice.

4.2 Installing the telescopic flue through the wall



WARNING:

Products of combustion!

To ensure products of combustions do not enter the property through the flue hole.

- ▶ Where possible the flue hole should be sealed to the building fabric on the inner and outer face using a suitable building material. As a minimum, the flue must be sealed to the inner wall using a suitable building material and the rubber collar fitted to the flue against the outside face. Providing the face of the outside wall is flat then the rubber collar is considered to be an adequate seal.

Fig. 1 Manual extract

This guidance essentially asks for any flue which passes through an external wall, and is accessible from both sides, to be sealed to the building on the inner and outer surfaces.

For installations where:

- Access to the terminal may be difficult to inspect behind the external sealing ring.
- The flue may have been installed from within the building without sealing the flue to the outer surface.
- It cannot be confirmed that the flue is sealed to the outside surface with a suitable building material.

The flue must be sealed to the inner surface of the wall and the outer rubber flue sealing ring must be fitted.

The rubber sealing ring provided for the outer surface is deemed an adequate weather seal to a flat, smooth surface. It will prevent rainwater or products of combustion from entering the building through the annular gap around the flue. It must be fitted as it helps to create a waterproof seal between the final section of flue pipe and the flue terminal.

The plastic ring provided for the inner wall is mainly for cosmetic purposes and does not have to be fitted, the inner wall can be finished using suitable building materials.

Our appliance installation manuals state that in the absence of specific guidance from the manufacturer, BS5440 must be followed.

Note: Up until now, the Installation Manuals have not been specific in detailing that the annular space must be sealed, and an installer may question a GIUSP classification. However the IM also states that BS 5440-1 must be complied with, so the following applies,

BS5440-1:2008 10.2.2 Jointing and weatherproofing.

Where flue duct components are required to be joined, the jointing methods and materials specified by the appliance manufacturer shall be used.

The annular space between the flue duct and air supply duct and their respective surrounding structures shall be sealed.

Any ingress of moisture shall be prevented from affecting the internal wall face.

Please refer to Fig 2 for further guidance in classifying flue sealing situations. Fig 2 refers specifically to methods applied when the standard Worcester sealing rings are provided. Please read Note 2 for specific guidance when sealing rings that are purpose made for sealing the annular gap around the flue are installed.

Fig. 2 Table

Wall sealing ring - Outer 8-716-111-212- 0	Wall finishing ring - Inner 8-716-111-211- 0	Sealed to external wall	Sealed to internal wall	Outcome
N	N	N	N	GIUSP
Y	N	N	N	GIUSP
Y	Y	N	N	GIUSP
N	Y	N	N	GIUSP
N	Y	N	Y*	GIUSP
N	N	N	Y*	GIUSP
Y	Y	Y	Y	acceptable
Y	Y	Y	N	acceptable
Y	Y	N	Y	acceptable
Y	N	Y	Y	acceptable
Y	N	N	Y	acceptable
Y	N	Y	N	NCS/Advice note
N	Y	Y	N	NCS/Advice note
N	Y	Y	Y	NCS/Advice note
N	N	Y	N	NCS/Advice note
N	N	Y	Y	NCS/Advice note

Note Ref Fig 2: Y* - GIUSP applies to cavity walls. Solid walls can be categorised as NCS/Advice note.

Flue terminal guards must always be fitted if the flue is less than 2m above pedestrian access or where there is a risk of vandalism or accidental damage.


Due to the position of the flue turret/adaptor on some Worcester boilers, certain flue configurations mean that it is impossible to avoid having an elbow socket partially buried within the building fabric.

This would apply to high level horizontal and left or right extended rear fluing horizontal configurations. It must not be applied to flue configurations simply to avoid cutting flue extensions to ensure the flue joints exposed.

The following information should be used as guidance. Any of the following solutions are permitted providing the guidance is adhered to.

To make good the inner wall face, either the decorative finishing ring provided with the flue, or fire stop plates can be used.


Fig. 3
Flue joints buried up to 40mm into the wall.



- Must have a core (or stitch drilled) hole through the inner wall large enough to allow sealing of the inner wall to the flue pipe beyond the made joint and allow visual inspection at future visits.
- The socket must be no deeper than 40mm into the wall and must not be buried more than half of the wall skin thickness.
- Joint securing screws must be fitted and visible.

- The inner wall finishing ring must be moveable to allow inspection of the joint.
- 1) Cavity walls: The flue pipe must be sealed to the inner wall skin with a suitable building material.
- 2) The flue pipe should be sealed to the outer wall skin with a suitable building material.
- Solid walls: The flue pipe must be sealed to the wall with a suitable building material.

Fig. 4
Flue joints buried further than 40mm into the wall.



- Must be sleeved from the finished inner to finished outer wall faces with a suitable oversized duct.
- The duct must be made good to the inner and outer wall with a suitable building material.
- The flue must be sealed to the duct beyond the joint socket with a suitable building material.
- The joint securing screws must be fitted and visible.
- The wall finishing ring must be moveable to inspect the joint.

Whilst it is always our intention to fully assist, it is essential to recognise that all information given by the company in response to an enquiry of any nature is provided in good faith and based upon the information provided with the enquiry. We recommend that advice should always be checked with your installer or contract partner. Consequently, the company cannot be held responsible for any liability relating to the use or repetition of such information or part thereof. In addition, whilst making every reasonable effort to monitor the performance and quality of our supply, installation and service network, we do not accept responsibility for the workmanship or operation of any third party company that the company may have promoted either in conversation, e-mail, or other communication. Similarly, the views and opinions expressed in communication with individuals within the company may not reflect that of the business as a whole.

You can find this, and all issued technical bulletins on the Worcester website at: www.worcester-bosch.co.uk/tb
or www.worcester-bosch.ie/tb

Fig. 5
Using FlueSnug to seal the flue to the building fabric.




There are now products available which are specifically designed for sealing flues to the building fabric. They **can** remove the need for any further sealing or making good. We accept that these products can be used with our Oilfit & Condensfit II flues providing they are installed in place of, and in the situations described for our own wall sealing rings.

For flue terminals finished at the face of the external wall, the sealing ring must be fitted into the locating groove on the terminal. (Ref TB 0148b)

Whilst these products meet the requirements for providing weather sealing and will prevent the ingress of flue gases from the terminal, they will not provide protection against lateral movement of the flue.

If a FlueSnug is used in this situation, and a flue extension is installed between the boiler flue adaptor and the final flue elbow, the flue extension must be securely bracketed within 150mm of the elbow. The elbow to terminal joint must be secured with screws, and the terminal section must either be sealed to the building using a suitable building material or a FlueSnug must be used on both the internal and external faces.

Fig. 6
Shows a FlueSnug used on the internal wall and the flue sealed to the outer wall.



- Manufacturers guidance must be followed when fitting third party products. A suitably sized core hole must be drilled for the application.
- Flue joint securing screws must be fitted and visible.
- There must be sufficient space to slide the wall seal back to inspect the flue joint.
- Any flue extensions must be bracketed. The last extension must be bracketed within 150mm of the final elbow.

The internal white decorative ring which we provide with horizontal flue terminals will not slide onto the socket section of our flues. If the socket is partially buried within the wall and you wish to use the decorative ring for making good, the inner lip can be carefully trimmed off with a sharp knife as shown below.

Alternatively, fire stop plates can be used:

60/100 8-718-006-907-0

80/125 8-716-110-276-0

Fig. 7



Whilst it is always our intention to fully assist, it is essential to recognise that all information given by the company in response to an enquiry of any nature is provided in good faith and based upon the information provided with the enquiry. We recommend that advice should always be checked with your installer or contract partner. Consequently, the company cannot be held responsible for any liability relating to the use or repetition of such information or part thereof. In addition, whilst making every reasonable effort to monitor the performance and quality of our supply, installation and service network, we do not accept responsibility for the workmanship or operation of any third party company that the company may have promoted either in conversation, e-mail, or other communication. Similarly, the views and opinions expressed in communication with individuals within the company may not reflect that of the business as a whole.

You can find this, and all issued technical bulletins on the Worcester website at: www.worcester-bosch.co.uk/tb
or www.worcester-bosch.ie/tb